



DATE: September 27, 1985

TO: [REDACTED]

EPA Region 5 Records Ctr.



298185

FROM: Eddy Lin

SUBJECT: Underground Tanks removal from Allied Amphenol Products
Cook/031030002
Broadview/Amphenol Products
Superfund/General Correspondence

On 9/25/85 I had a telephone conversation with Mr. Borton Fleischer of Amphenol Products (312-983-3500) regarding the removal of two underground storage tanks. Mr. Fleischer stated on the phone that the underground tanks removal was done by 9/20/85. No leaks were found on the tanks. No soil contamination was detected. The holes have been backfilled with concrete. Also, those two storage tanks were inside the building. That concluded our telephone conversation.

EL/vc

cc: Mary Dinkel
Chuck Gruntman
Cliff Gould/N. Region

RECEIVED
OCT 08 1985
IEPA-DLPC